P1 Port Certifier Professional ver 2.0 P1C-003 v.2.0

Professional P1 port tester, certifier and protocol analyser.



Description:

The P1C-003 device is designed to certify and test the P1 ports of Smart Meters.

It enables automatic verification of key electrical P1 port parameters and checks correctness of the data packet.

Tests can be performed automatically and their results stored in the device's memory.

Separate PC application allows the printing of a Test Report from executed tests.

Key features:

The device precisely measures and 1 tests most of the electrical parameters of the P1 port


Precise "+5V line" voltage tests. (load, 2 ripple and noise level tests)

TC-006 Ripple leve	PASSED I	Result: 00
ΛU[mŲ] - 100	time scale = Ripple level	
-50		
	logging	time→
06:58		3.77


3

4

Precise "+5V line" current tests e.g., maximal current, shot circuit current, inrush current



Able to simulate various P1 load conditions





5 6

"Data Request Line" tests

- 7 Parses and checks the correctness of the P1 data protocol
- 8 10 different fully configurable "Profiles", with predefined settings for DSMR 2.2, DSMR 4.0 and ESMR 5.0



 9 10 different, fully configurable "Test sets" (up to 20 "Test cases" in one test set)



10 Can be connected as a mass storage device via USB

 External PC application for editing "Profiles" and "Test Suits" as well as Test Report generation

P1C_003 P1 port certifier - application	xii 5.52 3.2014-12-01	é enez
Connetto PSC device Profile nanager Test suit nanager Report pene		
11		
1.1.3-		
Consett Disconnect		

12 Configurable "Test Reports" in .pdf format

Test report generated by "P1 port certification device"	6. TC details and graphs
	Note at the evented land are second.
STATISTICS AND ADDRESS AND ADDRESS ADDR	Neuros de Verences de la de ceuro. Neuros de recherco de la contractiva de la contractiva.
1). Document description	TC-N1 Voltage under load livet
This document prevents the test results executed by 'P1 Certifier device'.	The intendion of TC-001 is to sheek contractness of overload protection
The document is divided in number of sections.	mentarism. During the test, vistage on the "vity tine" is measured at continuousy increasing load.
Table of contents:	
	Read - PASSED
	Figure - Techana executed controlly No entry faced
2). Do test profile used during the test	
3). Test case set used during the test	No 101 Poilso Recoll 00 Recolling and a feet
4), TC Manis 5), Recorded delectam	A Dia) Raw Dia
6) Conclusion	
*; C2/C2/C1	•
2. F1 Cartifler device Information	
Provane 3.00 P10 Rev=3.0	A REPORT OF THE LOW BOAT OF
Firmers venion-10	
214001	
calibration_date=0014-10-04	
calibrated by-them	
2), Profile parameters used during the leef	Read TO BE
	TC-005 Variable load g 10me
profile_number=1	This lesislase simulates variable load on v/o/ line at period of 10 millioecond.
boweiko	The escale amounts variable cast on row the at pende of to measure.
Max visible or 5V Int-5.50	
Mn votage on 5V Ine+4.600 Roma Invent100	
Name www-100	Beauf - FAAAFD
	Reach - Testawe executed controls, to enors found,
Overtaid those=010	
RU 11 cobie resistance-0 180 Collegian period-10	Torontohis Acod Front # miller
Short ontiat max ownert+100.000	(4022) time - 10 mp . Rowson
Mail DATA require current=10.000	Res Louis Life et
DATA the perty events 1.000	
4). Test set used during the test	-
tet aut number-0	 REPORTS-158718-1132-823.137
tet auf name-para tet	
1 Volace under load test	
	the second
5 Variable thad do 16 5 Notice level of the trad	
6 Nose level at idle load 10 Data packet receptor	1000
	TC-054 Verteche load @ 130me
8). One page report	This bestudes amustes variable load on +01/ the all period of 100 millionand.
1 PASSED Vidios and initial Testias mendel soreth. No error fund	
3 PASSED Variable load @ 10ms Testcase executed correctly. No errors found.	
4 PASSED Variable cod di 120ms Testuale executed corrects. No errora found	Rest - PASSED
5 FAILED Variate load do to Minimal atorest votage exceeded	Reason - Testoase executed correctly. No errors found.
6 PASSED Nose ever al de cad Testoase executed conectly. No errors found.	
20142142 112040 1 47 6	2015-07-02 1126-00

- **13** Clear OLED display
- **14** Hi-capacity rechargeable LiPo battery on board (8 hours of work time without recharging)
- **15** Sound feedback
- **16** HW calibration port and SW calibration registers
- **17** Tested with all major smart meters available on the Dutch market